

Town of Lake Waccamaw

ON THE SHORES OF NORTH CAROLINA'S LARGEST NATURAL LAKE

P.O. Box 145
Lake Waccamaw, North Carolina 28450
(910) 646-3700
(910) 646-3860 Fax
Email: wwtplw@embarqmail.com



Member N.C. League of Municipalities

WASTEWATER TREATMENT PLANT PERFORMANCE ANNUAL REPORT (2017-2018)

I. General Information

Person in Charge/Contact: Michael Prostinak, ORC Wastewater Treatment Plant – 910-646-3700, NPDES Permit Number - NC0021881

II. Description of Treatment Process

Class II, 0.4 MGD Activated Sludge Wastewater Treatment with a bar screen, aeration basin, clarifier, two settling ponds, and two digesters for Sludge that is to be used in a compost process.

III. Performance

Test Summary of the System Performance for the period July 2017 – June 2018:


October 2017 – During the 3rd week of the month we exceeded the weekly average limit for BOD. The exact cause of this has not been determined but it is suspected that an excessive amount of sludge in the 1st Polishing Pond caused the violation.

IV. Notification


This report is being made available to system users by printing same in The News Reporter and posting on the Town's website at www.lakewaccamaw.com. Additional information or a copy of this report can be obtained by contacting the Town Hall at 910-646-3700.

V. Certification

I certify, under penalty of law, that this report is complete and accurate to the best of my knowledge. I further certify that this report has been made available to the users of the Lake Waccamaw WWTP and that the users were notified of its availability.



Gordon C. Hargrove, Town Manager


Date