

Town of Lake Waccamaw

ON THE SHORES OF NORTH CAROLINA'S LARGEST NATURAL LAKE



Member N.C. League of Municipalities

P.O. Box 145
Lake Waccamaw, North Carolina 28450
(910) 646-3700
(910) 646-3860 Fax
Email: wwtplw@embarqmail.com

SANITARY SEWER COLLECTION SYSTEM PERFORMANCE ANNUAL REPORT (2020-2021)

I. General Information

Person in Charge/Contact: Damon Kempfski, Town Manager; Robert Bailey, ORC, Lake Waccamaw Collection System. 910-646-3700.

II. Description of System

Class II Collection System consisting of both gravity lines and force main lines and 11 Lift Stations monitored/inspected by Town Staff on a daily basis.

III. Performance

During the fiscal year 2020-2021, the System transmitted an average of 219,215 gallons per day of wastewater to the Treatment Plant.

The Town reported Sanitary Sewer Overflows (SSO) in two specific areas throughout the year. Those areas were as follows:

- (1) Manhole at Dales Seafood Parking Lot
8/4/2020 – approximately 150 gallons
12/31/2020 – approximately 400 gallons

- (2) Manhole at North end of Mt Zion St.
8/4/2020 – approximately 300 gallons
1/1/2021 – approximately 300 gallons

The spills listed above were results of heavy rainfall.

The Town also reported two other spills:

- (1) 476 Bella Coola Rd. on 8/21/2020 = approximately 30 gallons
- (2) 1032 Bella Coola Rd. on 5/9/2021 = approximately 40 gallons

These spills were caused by pipe failures.

All spills were dealt with by Town staff and caused no negative environmental impacts.

Further information or a copy of this report is available at Town Hall.

I certify, under penalty of law, that this report is complete and accurate to the best of my knowledge. I further certify that this report has been made available to the users or customers of the named system and that those users have been notified of its availability.

Damon Kempinski, Town Manager

Date